

Quarterly Inspection -- HE-301

Document ID: INSP-HE301-2025-Q4

Inspection period: Q4 2025 (Oct-Dec 2025)
Inspector: Ananya Iyer, Reliability Engineer
Authority Level: 4 (Site Inspection Record)

Findings

Design/operating pressure reference	18.5 bar (per SOP on file at time of inspection)
External condition	Satisfactory - no visible corrosion or leakage
Tubesheet condition	Satisfactory - within acceptable wear tolerance
Result	Pass - no immediate corrective action required

Note

This record references the 18.5 bar operating pressure specification current at the time of inspection.
Superseded by OEM bulletin MHT-PB-2026-11 (2026-06-01); flagged for review under blast-radius analysis.