

Mechanical Seal Specification Revision -- EQ-1xx Series Centrifugal Pumps

Document ID: FP-SB-2025-04

Issue date: 2025-01-15 | Supersedes: none (first revision of this specification)

Distribution: All operators of EQ-1xx series centrifugal pumps

Authority Level: 3 (OEM Manual / Bulletin)

Subject

Effective 2025-01-15, the mechanical seal part number for EQ-1xx series pumps is revised from FSL-2240A to FSL-2240B.

Reason for Revision

Field service reports across the installed base indicated accelerated seal face wear under thermal cycling conditions with the FSL-2240A seal. The revised FSL-2240B seal uses an updated face material with improved tolerance to repeated thermal cycling.

Action Required

- All EQ-1xx series pumps should be updated to FSL-2240B at the next scheduled maintenance event.
- Any failure-driven seal replacement occurring after this bulletin date should use FSL-2240B, not the superseded FSL-2240A.
- Maintenance stores should update inventory to stock FSL-2240B and phase out remaining FSL-2240A stock.

Note

This bulletin does not itself trigger a mandatory shutdown. It applies at the next maintenance touchpoint for each affected asset.