

Maximum Operating Pressure Revision -- HE-3xx Series Shell and Tube Heat Exchangers

Document ID: MHT-PB-2026-11

Issue date: 2026-06-01 | Supersedes: MHT-PB-2022-07

Distribution: All operators of HE-3xx series heat exchangers

Authority Level: 3 (OEM Manual / Bulletin)

Subject

Effective 2026-06-01, the maximum allowable operating pressure for HE-3xx series heat exchangers is revised from 18.5 bar to 16.2 bar.

Reason for Revision

A revised fatigue analysis (ref. mechanical integrity assessment MHT-ENG-2026-03) following an industry-wide review of tubesheet design margins identified a reduced safe operating envelope for this series under sustained cyclic loading.

Action Required

- All facilities operating HE-3xx series equipment must update associated site operating procedures, inspection records, and hydrotest specifications to reflect the revised 16.2 bar limit.
- Continued operation above 16.2 bar is not authorized after 2026-09-01 (90-day transition window from bulletin date).
- Facilities should conduct a documentation review to identify all procedures and records referencing the superseded 18.5 bar limit.

Note

This is a safety-critical parameter change. Sites should route this through formal Management of Change rather than administrative document correction.