

Normal Operation -- HE-301 Shell and Tube Heat Exchanger

Document ID: SOP-HE-301-04

Issued: 2023-09-01 | Last reviewed: 2025-09-01 | Next review due: 2027-09-01

Applicable equipment: HE-301

Authority Level: 4 (Site Operating Procedure)

1. Purpose

This procedure defines normal operating parameters and monitoring requirements for HE-301 Shell and Tube Heat Exchanger.

2. Operating Parameters

Maximum operating pressure	18.5 bar (per OEM bulletin MHT-PB-2022-07)
Normal operating pressure range	12 - 16 bar
Maximum operating temperature	180 degC

3. Monitoring

Operators shall log pressure and temperature readings each shift. Any reading exceeding the maximum operating pressure shall be reported immediately to the Shift Lead.

4. Note on Pending Revision

OEM bulletin MHT-PB-2026-11 (issued 2026-06-01) has revised the maximum operating pressure for this equipment class to 16.2 bar. This procedure is pending update via Management of Change; the 18.5 bar figure above reflects the version currently on file.