

RAJGARH PETROCHEMICAL COMPLEX - INSPECTION RECORD

Document INSP-V247-2026-Q3 | RPC-L3-S2-V247 | 14-Jul-2026

Inspection reference:	INSP-V247-2026-Q3
Asset tag:	V-247
Functional location:	RPC-L3-S2-V247
Description:	Manual Isolation Valve
Inspection date:	14-Jul-2026
Inspector:	Suresh Yadav
Interval:	18 months
Next due:	20-Sep-2027
Result:	Satisfactory - no defects recorded

1. SCOPE

Routine interval inspection of manual isolation valve V-247 at RPC-L3-S2-V247.

2. FINDINGS

Body and bonnet free of external corrosion. Operated through full travel without binding. Seat leakage test passed at the rated differential. Gland packing shows no weeping. Position indicator agrees with valve state.

3. ISOLATION BOUNDARY NOTE

V-247 forms part of the Line 3 Section 2 isolation boundary used for permit to work. No change to the boundary configuration was made during this inspection.

4. RESULT

Accepted for continued service. Next inspection due 20-Sep-2027 on the standing 18 month interval.