

RAJGARH PETROCHEMICAL COMPLEX - INSPECTION RECORD

Document INSP-XV203-2026-Q3 | RPC-L3-S2-XV203 | 14-Jul-2026

Inspection reference:	INSP-XV203-2026-Q3
Asset tag:	XV-203
Functional location:	RPC-L3-S2-XV203
Description:	Primary Isolation Valve
Inspection date:	14-Jul-2026
Inspector:	Suresh Yadav
Interval:	18 months
Next due:	12-Nov-2026
Result:	Satisfactory - no defects recorded

1. SCOPE

Routine interval inspection of primary isolation valve XV-203 at RPC-L3-S2-XV203.

2. FINDINGS

Body and bonnet free of external corrosion. Operated through full travel without binding. Seat leakage test passed at the rated differential. Gland packing shows no weeping. Position indicator agrees with valve state.

3. ISOLATION BOUNDARY NOTE

XV-203 forms part of the Line 3 Section 2 isolation boundary used for permit to work. No change to the boundary configuration was made during this inspection.

4. RESULT

Accepted for continued service. Next inspection due 12-Nov-2026 on the standing 18 month interval.