

RAJGARH PETROCHEMICAL COMPLEX - WORK ORDER CLOSEOUT

Document WO-2026-0779-CO | RPC-U1-HE303 | Closed 16-Jul-2026

Work order:	WO-2026-0779
Asset tag:	HE-303
Functional location:	RPC-U1-HE303
Description:	Shell and Tube Heat Exchanger
Opened:	15-Jul-2026
Closed:	16-Jul-2026
Technician:	Suresh Yadav
Verified by:	Ananya Iyer, Reliability Engineer
Total downtime:	9.5 hours

1. WORK PERFORMED

Planned maintenance executed on HE-303 at RPC-U1-HE303. Asset isolated and returned to service the following shift. Condition on strip-down was consistent with the approach temperature alarm threshold guidance issued under MHT-PB-2026-25.

2. PARTS AND CONSUMABLES

Component HE-3xx series confirmed as the fitted revision. No superseded part numbers were drawn from stores for this work order.

3. INSTALLATION RECORD

Trend review interval set to weekly, within the qualified range and below the monthly limit. Post-work run test completed with no exception raised.

4. RELIABILITY NOTE

Reliability engineering to fold the approach temperature alarm threshold of 8 degrees C into the planned maintenance schedule for HE-303 at the next review.