

Veridian Petrochemicals
Bharuch Complex

Document no: CLC-GL-MM Revision: A
Title: Installation and maintenance manual, CLC-GL control valves
Owner: Dr. Sunita Rao
Issued: 25 July 2024

Primary equipment: FV-1101, Flow control valve 1

Applies to control valves FV-1101 to FV-1106 and FV-2101 to FV-2104. Globe body, pneumatic actuator, digital positioner. Full stroke time 6 seconds. Deadband should not exceed 1 percent of span; a deadband above 2 percent indicates stiction and calls for packing replacement. Positioner calibration every 12 months.