

Veridian Petrochemicals
Bharuch Complex

Document no: DS-AT-2101-2022 Revision: A
Title: Equipment datasheet, AT-2101
Owner: Dr. Sunita Rao
Issued: 27 April 2022

Primary equipment: AT-2101, Hydrogen purity

Manufacturer: Calder Controls. Model: CLC series D. Serial number: SN-AT-2101-2008.
Installed: 2008. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet nine.

Smart transmitter, 4 to 20 mA with HART, range 0 to 250 percent.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.