

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-1101-2023 Revision: A
Title: Equipment datasheet, FV-1101
Owner: Dr. Sunita Rao
Issued: 08 October 2023

Primary equipment: FV-1101, Flow control valve 1

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-FV-1101-2015.
Installed: 2015. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet one.

Globe control valve, DN80, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.