

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-1102-2022 Revision: A
Title: Equipment datasheet, FV-1102
Owner: Dr. Sunita Rao
Issued: 27 July 2022

Primary equipment: FV-1102, Flow control valve 2

Manufacturer: Calder Controls. Model: CLC series D. Serial number: SN-FV-1102-2015.
Installed: 2015. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet four.

Globe control valve, DN150, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.