

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-1103-2024 Revision: A
Title: Equipment datasheet, FV-1103
Owner: Dr. Sunita Rao
Issued: 09 December 2024

Primary equipment: FV-1103, Flow control valve 3

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-FV-1103-2015.
Installed: 2015. Unit: CDU. Criticality: non critical. Piping and instrument diagram: CDU
unit, sheet two.

Globe control valve, DN80, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.