

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-1104-2022 Revision: A
Title: Equipment datasheet, FV-1104
Owner: Dr. Sunita Rao
Issued: 01 February 2022

Primary equipment: FV-1104, Flow control valve 4

Manufacturer: Calder Controls. Model: CLC series D. Serial number: SN-FV-1104-2009.
Installed: 2009. Unit: CDU. Criticality: non critical. Piping and instrument diagram: CDU
unit, sheet six.

Globe control valve, DN150, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.