

Veridian Petrochemicals  
Bharuch Complex

Document no: DS-FV-1105-2024 Revision: A  
Title: Equipment datasheet, FV-1105  
Owner: Dr. Sunita Rao  
Issued: 28 October 2024

Primary equipment: FV-1105, Flow control valve 5

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-FV-1105-2017.  
Installed: 2017. Unit: CDU. Criticality: non critical. Piping and instrument diagram: CDU  
unit, sheet nine.

Globe control valve, DN150, equal percentage trim.  
Actuator: pneumatic diaphragm, fail closed.  
Positioner: smart, HART.