

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-1106-2024 Revision: A
Title: Equipment datasheet, FV-1106
Owner: Dr. Sunita Rao
Issued: 16 February 2024

Primary equipment: FV-1106, Flow control valve 6

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-FV-1106-2017.
Installed: 2017. Unit: CDU. Criticality: non critical. Piping and instrument diagram: CDU
unit, sheet six.

Globe control valve, DN50, equal percentage trim.
Actuator: pneumatic diaphragm, fail open.
Positioner: smart, HART.