

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-2101-2023 Revision: A
Title: Equipment datasheet, FV-2101
Owner: Dr. Sunita Rao
Issued: 13 September 2023

Primary equipment: FV-2101, Hydrogen control valve 1

Manufacturer: Calder Controls. Model: CLC series A. Serial number: SN-FV-2101-2019.
Installed: 2019. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet two.

Globe control valve, DN80, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.