

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-2102-2023 Revision: A
Title: Equipment datasheet, FV-2102
Owner: Dr. Sunita Rao
Issued: 22 July 2023

Primary equipment: FV-2102, Hydrogen control valve 2

Manufacturer: Calder Controls. Model: CLC series E. Serial number: SN-FV-2102-2014.
Installed: 2014. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet seven.

Globe control valve, DN150, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.