

Veridian Petrochemicals
Bharuch Complex

Document no: DS-FV-2104-2022 Revision: A
Title: Equipment datasheet, FV-2104
Owner: Dr. Sunita Rao
Issued: 17 August 2022

Primary equipment: FV-2104, Hydrogen control valve 4

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-FV-2104-2017.
Installed: 2017. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet nine.

Globe control valve, DN150, equal percentage trim.
Actuator: pneumatic diaphragm, fail closed.
Positioner: smart, HART.