

Veridian Petrochemicals
Bharuch Complex

Document no: DS-LT-1101-2024 Revision: A
Title: Equipment datasheet, LT-1101
Owner: Dr. Sunita Rao
Issued: 11 November 2024

Primary equipment: LT-1101, Column bottom level

Manufacturer: Calder Controls. Model: CLC series C. Serial number: SN-LT-1101-2012.
Installed: 2012. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet two.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 degC.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.