

Veridian Petrochemicals
Bharuch Complex

Document no: DS-LT-1102-2023 Revision: A
Title: Equipment datasheet, LT-1102
Owner: Dr. Sunita Rao
Issued: 15 April 2023

Primary equipment: LT-1102, Desalter interface level

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-LT-1102-2010.
Installed: 2010. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet three.

Smart transmitter, 4 to 20 mA with HART, range 0 to 10 m³/h.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.