

Veridian Petrochemicals
Bharuch Complex

Document no: DS-LT-1103-2022 Revision: A
Title: Equipment datasheet, LT-1103
Owner: Dr. Sunita Rao
Issued: 01 July 2022

Primary equipment: LT-1103, Reflux drum level

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-LT-1103-2008.
Installed: 2008. Unit: CDU. Criticality: non critical. Piping and instrument diagram: CDU
unit, sheet eight.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 barg.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.