

Veridian Petrochemicals
Bharuch Complex

Document no: DS-LT-4101-2024 Revision: A
Title: Equipment datasheet, LT-4101
Owner: Dr. Sunita Rao
Issued: 29 February 2024

Primary equipment: LT-4101, Knock-out drum level

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-LT-4101-2016.
Installed: 2016. Unit: FLR. Criticality: safety critical. Piping and instrument diagram: FLR
unit, sheet nine.

Smart transmitter, 4 to 20 mA with HART, range 0 to 40 barg.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.