

Veridian Petrochemicals
Bharuch Complex

Document no: DS-PT-1101-2022 Revision: A
Title: Equipment datasheet, PT-1101
Owner: Dr. Sunita Rao
Issued: 23 August 2022

Primary equipment: PT-1101, Column top pressure

Manufacturer: Calder Controls. Model: CLC series A. Serial number: SN-PT-1101-2018.
Installed: 2018. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet four.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 degC.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.