

Veridian Petrochemicals
Bharuch Complex

Document no: DS-PT-2101-2023 Revision: A
Title: Equipment datasheet, PT-2101
Owner: Dr. Sunita Rao
Issued: 09 September 2023

Primary equipment: PT-2101, Reactor inlet pressure

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-PT-2101-2018.
Installed: 2018. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet three.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 m³/h.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.