

Veridian Petrochemicals
Bharuch Complex

Document no: DS-TT-1101-2023 Revision: A
Title: Equipment datasheet, TT-1101
Owner: Dr. Sunita Rao
Issued: 29 August 2023

Primary equipment: TT-1101, Column top temperature

Manufacturer: Calder Controls. Model: CLC series G. Serial number: SN-TT-1101-2016.
Installed: 2016. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet seven.

Smart transmitter, 4 to 20 mA with HART, range 0 to 250 m³/h.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.