

Veridian Petrochemicals
Bharuch Complex

Document no: DS-TT-1102-2022 Revision: A
Title: Equipment datasheet, TT-1102
Owner: Dr. Sunita Rao
Issued: 20 October 2022

Primary equipment: TT-1102, Heater outlet temperature

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-TT-1102-2013.
Installed: 2013. Unit: CDU. Criticality: critical. Piping and instrument diagram: CDU unit,
sheet three.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 m³/h.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.