

Veridian Petrochemicals
Bharuch Complex

Document no: DS-TT-2101-2022 Revision: A
Title: Equipment datasheet, TT-2101
Owner: Dr. Sunita Rao
Issued: 11 May 2022

Primary equipment: TT-2101, Reactor bed 1 temperature

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-TT-2101-2012.
Installed: 2012. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit, sheet four.

Smart transmitter, 4 to 20 mA with HART, range 0 to 40 percent.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.