

Veridian Petrochemicals
Bharuch Complex

Document no: DS-TT-2102-2023 Revision: A
Title: Equipment datasheet, TT-2102
Owner: Dr. Sunita Rao
Issued: 30 April 2023

Primary equipment: TT-2102, Reactor bed 2 temperature

Manufacturer: Calder Controls. Model: CLC series G. Serial number: SN-TT-2102-2013.
Installed: 2013. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit, sheet seven.

Smart transmitter, 4 to 20 mA with HART, range 0 to 250 degC.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.