

Veridian Petrochemicals

Dahej Tank Farm

Document no: DS-TT-6101-2024 Revision: A

Title: Equipment datasheet, TT-6101

Owner: Dr. Sunita Rao

Issued: 30 July 2024

Primary equipment: TT-6101, Tank 1 temperature

Manufacturer: Calder Controls. Model: CLC series C. Serial number: SN-TT-6101-2010.

Installed: 2010. Unit: TKF. Criticality: critical. Piping and instrument diagram: TKF unit, sheet six.

Smart transmitter, 4 to 20 mA with HART, range 0 to 250 percent.

Diaphragm: stainless steel; enclosure rated for the area.

Loop checked from the field to the control system.