

Veridian Petrochemicals
Dahej Tank Farm

Document no: DS-TT-6104-2023 Revision: A
Title: Equipment datasheet, TT-6104
Owner: Dr. Sunita Rao
Issued: 01 August 2023

Primary equipment: TT-6104, Tank 4 temperature

Manufacturer: Calder Controls. Model: CLC series G. Serial number: SN-TT-6104-2015.
Installed: 2015. Unit: TKF. Criticality: critical. Piping and instrument diagram: TKF unit,
sheet one.

Smart transmitter, 4 to 20 mA with HART, range 0 to 100 degC.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.