

Veridian Petrochemicals
Bharuch Complex

Document no: DS-VT-2101A-2024 Revision: A
Title: Equipment datasheet, VT-2101A
Owner: Dr. Sunita Rao
Issued: 04 March 2024

Primary equipment: VT-2101A, Compressor A vibration

Manufacturer: Calder Controls. Model: CLC series C. Serial number: SN-VT-2101A-2016.
Installed: 2016. Unit: HDT. Criticality: critical. Piping and instrument diagram: HDT unit,
sheet three.

Smart transmitter, 4 to 20 mA with HART, range 0 to 40 degC.
Diaphragm: stainless steel; enclosure rated for the area.
Loop checked from the field to the control system.