

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-1101-2025 Revision: A
Title: Equipment datasheet, XV-1101
Owner: Dr. Sunita Rao
Issued: 10 January 2025

Primary equipment: XV-1101, Emergency isolation valve 1

Manufacturer: Calder Controls. Model: CLC series H. Serial number: SN-XV-1101-2015.
Installed: 2015. Unit: CDU. Criticality: safety critical. Piping and instrument diagram: CDU
unit, sheet seven.

Ball valve, DN150, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.