

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-1104-2022 Revision: A
Title: Equipment datasheet, XV-1104
Owner: Dr. Sunita Rao
Issued: 05 December 2022

Primary equipment: XV-1104, Emergency isolation valve 4

Manufacturer: Calder Controls. Model: CLC series C. Serial number: SN-XV-1104-2015.
Installed: 2015. Unit: CDU. Criticality: safety critical. Piping and instrument diagram: CDU
unit, sheet five.

Gate valve, DN150, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.