

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-2101-2023 Revision: A
Title: Equipment datasheet, XV-2101
Owner: Dr. Sunita Rao
Issued: 27 August 2023

Primary equipment: XV-2101, Reactor isolation valve 1

Manufacturer: Calder Controls. Model: CLC series H. Serial number: SN-XV-2101-2015.
Installed: 2015. Unit: HDT. Criticality: safety critical. Piping and instrument diagram: HDT
unit, sheet three.

Gate valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.