

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-2102-2024 Revision: A
Title: Equipment datasheet, XV-2102
Owner: Dr. Sunita Rao
Issued: 01 August 2024

Primary equipment: XV-2102, Reactor isolation valve 2

Manufacturer: Calder Controls. Model: CLC series A. Serial number: SN-XV-2102-2019.
Installed: 2019. Unit: HDT. Criticality: safety critical. Piping and instrument diagram: HDT
unit, sheet eight.

Gate valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.