

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-2103-2022 Revision: A
Title: Equipment datasheet, XV-2103
Owner: Dr. Sunita Rao
Issued: 15 September 2022

Primary equipment: XV-2103, Reactor isolation valve 3

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-XV-2103-2017.
Installed: 2017. Unit: HDT. Criticality: safety critical. Piping and instrument diagram: HDT
unit, sheet seven.

Gate valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.