

Veridian Petrochemicals  
Bharuch Complex

Document no: DS-XV-3101-2023 Revision: A  
Title: Equipment datasheet, XV-3101  
Owner: Dr. Sunita Rao  
Issued: 21 June 2023

Primary equipment: XV-3101, Steam isolation valve 1

Manufacturer: Calder Controls. Model: CLC series H. Serial number: SN-XV-3101-2011.  
Installed: 2011. Unit: UTL. Criticality: critical. Piping and instrument diagram: UTL unit,  
sheet one.

Ball valve, DN150, class 300.  
Actuator: pneumatic spring return, fail closed.  
Fire safe design; position indicated at the valve.