

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-3102-2025 Revision: A
Title: Equipment datasheet, XV-3102
Owner: Dr. Sunita Rao
Issued: 27 April 2025

Primary equipment: XV-3102, Steam isolation valve 2

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-XV-3102-2018.
Installed: 2018. Unit: UTL. Criticality: critical. Piping and instrument diagram: UTL unit,
sheet three.

Ball valve, DN200, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.