

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-3103-2023 Revision: A
Title: Equipment datasheet, XV-3103
Owner: Dr. Sunita Rao
Issued: 09 October 2023

Primary equipment: XV-3103, Steam isolation valve 3

Manufacturer: Calder Controls. Model: CLC series D. Serial number: SN-XV-3103-2012.
Installed: 2012. Unit: UTL. Criticality: critical. Piping and instrument diagram: UTL unit, sheet one.

Ball valve, DN80, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.