

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-4101-2024 Revision: A
Title: Equipment datasheet, XV-4101
Owner: Dr. Sunita Rao
Issued: 05 October 2024

Primary equipment: XV-4101, Flare header isolation valve

Manufacturer: Calder Controls. Model: CLC series G. Serial number: SN-XV-4101-2009.
Installed: 2009. Unit: FLR. Criticality: safety critical. Piping and instrument diagram: FLR
unit, sheet seven.

Ball valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.