

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-5101-2025 Revision: A
Title: Equipment datasheet, XV-5101
Owner: Dr. Sunita Rao
Issued: 21 February 2025

Primary equipment: XV-5101, Dispatch isolation valve 1

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-XV-5101-2018.
Installed: 2018. Unit: BLD. Criticality: critical. Piping and instrument diagram: BLD unit, sheet four.

Gate valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.