

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-5102-2022 Revision: A
Title: Equipment datasheet, XV-5102
Owner: Dr. Sunita Rao
Issued: 08 November 2022

Primary equipment: XV-5102, Dispatch isolation valve 2

Manufacturer: Calder Controls. Model: CLC series H. Serial number: SN-XV-5102-2010.
Installed: 2010. Unit: BLD. Criticality: critical. Piping and instrument diagram: BLD unit, sheet nine.

Gate valve, DN80, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.