

Veridian Petrochemicals
Bharuch Complex

Document no: DS-XV-5103-2024 Revision: A
Title: Equipment datasheet, XV-5103
Owner: Dr. Sunita Rao
Issued: 19 October 2024

Primary equipment: XV-5103, Dispatch isolation valve 3

Manufacturer: Calder Controls. Model: CLC series F. Serial number: SN-XV-5103-2009.
Installed: 2009. Unit: BLD. Criticality: critical. Piping and instrument diagram: BLD unit,
sheet six.

Gate valve, DN100, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.