

Veridian Petrochemicals
Dahej Tank Farm

Document no: DS-XV-6104-2022 Revision: A
Title: Equipment datasheet, XV-6104
Owner: Dr. Sunita Rao
Issued: 02 June 2022

Primary equipment: XV-6104, Tank outlet valve 4

Manufacturer: Calder Controls. Model: CLC series B. Serial number: SN-XV-6104-2022.
Installed: 2022. Unit: TKF. Criticality: critical. Piping and instrument diagram: TKF unit,
sheet six.

Ball valve, DN200, class 300.
Actuator: pneumatic spring return, fail closed.
Fire safe design; position indicated at the valve.