

Veridian Petrochemicals
Bharuch Complex

Document no: FAIL-FV-1103-2026 Revision: A
Title: Failure history card, FV-1103
Owner: Neha Kulkarni
Issued: 25 September 2026

Primary equipment: FV-1103, Flow control valve 3

06 August 2026: work order raised on FV-1103. Valve sticks on small moves, controller output cycling. Repaired by Dinesh Patel, equipment returned to service.

31 August 2026: work order raised on FV-1103. Valve sticks on small moves, controller output cycling. Repaired by Anita Chauhan, equipment returned to service.

24 September 2026: work order raised on FV-1103. Valve sticks on small moves, controller output cycling. Repaired by Anita Chauhan, equipment returned to service.

This is failure 3 in 58 days on FV-1103, roughly every 19 days. The failure is recurring: the cause has not been removed by the repairs so far, and a reliability review of the duty is recommended.