

Veridian Petrochemicals
Bharuch Complex

Document no: FAIL-P-1102A-2026 Revision: A
Title: Failure history card, P-1102A
Owner: Neha Kulkarni
Issued: 17 September 2026

Primary equipment: P-1102A, Reflux pump A

14 August 2026: work order raised on P-1102A. Mechanical seal leaking at the gland, product visible on the baseplate. Repaired by Dinesh Patel, equipment returned to service.

16 September 2026: work order raised on P-1102A. Seal flush line weeping, barrier fluid level dropping. Repaired by Anita Chauhan, equipment returned to service.

This is failure 2 in 50 days on P-1102A, roughly every 25 days. The failure is recurring: the cause has not been removed by the repairs so far, and a reliability review of the duty is recommended.