

Veridian Petrochemicals
Bharuch Complex

Document no: HFS-CP-150-315-OM Revision: C
Title: Operation and maintenance manual, HFS-CP 150-315 centrifugal pump
Owner: Dr. Sunita Rao
Issued: 16 April 2024

Primary equipment: P-1101A, Crude feed pump A

Applies to pumps P-1101A and P-1101B (crude feed), P-1102A and P-1102B (reflux) and P-1103A and P-1103B (bottoms).

Design data. Design pressure 24 barg, design temperature 360 degC, rated flow 310 m³/h, rated head 148 m. Mechanical seal HAL-MS-4471 revision B, double seal with API Plan 53B barrier fluid at 2.5 bar above process pressure.

Lubrication. Bearing housings use ISO VG 68 oil; change oil every 4,000 operating hours. Bearing temperature alarm 85 degC, trip 95 degC.

Minimum continuous flow is 120 m³/h. Operation below this causes recirculation and seal face damage.

Seal inspection interval 8,000 operating hours. Alignment tolerance 0.05 mm total indicator reading.