

Veridian Petrochemicals
Dahej Tank Farm

Document no: HFS-FW-OM Revision: A
Title: Operation manual, HFS-FW diesel-driven fire water pump
Owner: Dr. Sunita Rao
Issued: 07 January 2024

Primary equipment: P-6201A, Fire water pump A

Applies to P-6201A, P-6201B and P-6201C. Rated flow 410 m³/h at 10.5 barg. Diesel engine starts on fire main pressure below 7.0 barg; weekly test run of 30 minutes at rated speed. Battery banks to be replaced every 3 years. Fuel tank to be kept above 80 percent.