

Veridian Petrochemicals
Bharuch Complex

Document no: HFS-SB-2026-02-BEARING-TEMPERATURE Revision: A
Title: Halden Fluid Systems service bulletin: bearing temperature alarm for P-3101A
Owner: Halden Fluid Systems
Issued: 16 August 2026

Primary equipment: P-3101A, Cooling water pump A

Service bulletin HFS-SB-2026 revision A, issued by Halden Fluid Systems.

Subject. Revision of the bearing temperature alarm for P-3101A.

The previously published value of 85 degC is withdrawn. The bearing temperature alarm for P-3101A is now 80 degC. Operators must update site procedures and records that quote the old value. This bulletin supersedes the value in the operation manual.