

Veridian Petrochemicals
Bharuch Complex

Document no: INSP-H-1101-TUBE-SURVEY Revision: A
Title: Radiant tube survey of fired heater H-1101
Owner: Gopal Iyer
Issued: 15 June 2026

Primary equipment: H-1101, Crude charge heater

Inspector: Gopal Iyer
Equipment: H-1101

Findings. Eight tubes show creep bulging below 2 percent. Tube skin thermocouples TT-1102 indicates a hottest tube at 588 degC. Two tubes on pass 3 flagged for replacement at the next turnaround. Result: conditional.